



SHREE SIDDHIVINAYAK AQUA SOLUTIONS

(AN ISO 9001:2015 CERTIFIED LABORATORY)

TEST REPORT

Report No / URL No : SSAS/20250430061
 Sample Receipt Date : 26-04-2025
 Analysis Start Date : 26-04-2025 To 30-04-2025
 Date of Report Issue : 30-04-2025
 Sample Collected by : Lab Person (MR VISHAL)
 Issued To : Clara Global School
 Sample Code No : SSAS/2025/04/26/059
 Sample Description : Water
 Sample Condition : Satisfactory
 Sample Type & Qty. : Water Sample, 1 lit
 Sample Marked As : Drinking Water
 Survey No, 20, Pandurang Industrial Area, Vadgaon Budruk, Pune 411041

Sr. No.	Parameters Tested	Units	Results	IS: 10500-2012 (Second Revision)	Test Method
				Requirement (Acceptable Limits)	
PHYSICO-CHEMICAL					
1	Odour	--	Agreeable	Agreeable	IS: 3025 Part-05
2	Taste	--	Agreeable	Agreeable	IS: 3025 Part-07
3	Turbidity	NTU	< 0.1	1	IS: 3025 Part-10
4	pH	--	7.13	6.5 To 8.5	IS: 3025 Part-11
5	Total Dissolved Solids	mg/l	26	Max 500	IS: 3025 Part-16
6	Total Hardness as CaCO ₃	mg/l	12.4	Max 200	IS: 3025 Part-21
7	Calcium as Ca++	mg/l	5.9	Max 75	IS: 3025 Part-02
8	Magnesium as Mg ++	mg/l	< 2.0	Max 30	IS: 3025 Part-02
9	Total Alkalinity as CaCO ₃	mg/l	< 10.0	Max 200	IS: 3025 Part- 23
10	Chloride as Cl-	mg/l	< 5.0	Max 250	IS: 3025 Part- 32
11	Fluoride as F-	mg/l	< 0.1	Max 1	IS: 3025 Part - 60
12	Free Residual Chlorine	mg/l	< 0.2	#	IS: 3025 Part - 26
BACTERIOLOGICAL					
13	Total Coliform	MPN/100 ml	Not Detected	Shall not be detectable in any 100 ml sample	IS: 1622
14	Faecal Coliform	MPN/100 ml	Not Detected	Shall not be detectable in any 100 ml sample	IS: 1622
15	E. coli in 100 ml of sample	--	Absent	Shall not be detectable in any 100 ml sample	IS: 1622

Remarks :

- The above Water Sample FIT FOR DRINKING PURPOSE to IS: 10500-2012(Second Revision) Drinking Water Specification with respect to the test conducted.
- The results relate to parameters tested.

Notes :

- # To be applicable only when water is chlorinated, minimum 0.2 mg/l.
- The result are related to the sample(s) tested only.
- Contents of this report are meant for your guidance & should not be used for advertisement, evidence or litigation.
- This Test Report shall not be reproduced in full or part, without the written approval of SSAS Laboratory.
- Total Liability of our Institution is limited to the Invoice Amount / Testing Charges.
- SSAS Laboratory is not responsible for the authenticity of photocopied or scanned report.
- Subject to Pune Jurisdiction.

----- End of Report -----


 Authorised Signatory

+91-9561889433

SR. No. 49/1, Rajvihar Society,
 Undri, Pune 411060

contact@ssaslab.com
 siddhivinayakaqua@gmail.com
 www.siddhivinayakaqua.com

APPENDIX-VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. SSAS/20250430016

Date :30/04/2025

It is certified that an inspection team headed by Mr Vishal Doke – Technical Head From SSAS Laboratory inspected the Clara Global School, Survey No. 20, Pandurang Industrial Area, Vadgaon Budruk, Pune 411041 on 26/04/2025 and found that the Clara Global School, Survey No. 20, Pandurang Industrial Area, Vadgaon Budruk, Pune 411041 has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year

Signature with Seal:



Name : VISHAL DOKE

Designation : Technical Head

To

Clara Global School,

Survey No. 20, Pandurang Industrial Area, Vadgaon Budruk, Pune 411041

(Name & Address of the Institution)